


**Occupancy Sensor**

NOTE: Occupancy sensor must provide a Normally Open (N/O) dry contact output, where an open contact indicates an unoccupied space and a closed contact indicates an occupied space.  
 (example: Lutron LOS-CDT-500R-WH)

TS250H

24VAC Power Wire -----  
 Communication Wire —————

DRAWN BY	CHECKED	DATE	SCALE	SHEET NO.
		10/12/2016	NTA	1 of 1